

Memo No:- 502

Date:- 02/04/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	FBD/04708/3/2025	Sample Details	Date & Time
Sample Classification:	Private		
Sender:	SHIV NADAR SCHOOL	Collected By	Shiv Nadar Sch...,9897026248
Location :-	, SECTOR-82	Collection Date	25/03/2025 at 15:06
Latitude :-	77.351711	Received at lab	26/03/2025 at 16:56
Longitude :-	28.393533	Tested at Lab	02/04/2025

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in FARIDABAD lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



VANDANA DESWAL,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY,FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

-----End of Report-----.